

# DUMPSBOSS.

## BICSI Installer 2 - Copper Exam

BICSI INSTC V7

Version Demo

Total Demo Questions: 10

Total Premium Questions: 116

Buy Premium PDF

<https://dumpsboss.co>

[support@dumpsboss.co](mailto:support@dumpsboss.co)

support@dumpsboss.co  
dumpsboss.co

## QUESTION NO: 1

A third 90-degree bend may be permitted in a conduit run if one of the bends is located within of the cable feed end?

- A. 300 mm (12")
- B. 375 mm (15")
- C. 450 mm (18")
- D. 483mm (19")

ANSWER: A

## QUESTION NO: 2

Which of the following is a floor serving space that serves as a point of termination for horizontal and backbone cables?

- A. EF
- B. ER
- C. TR
- D. TE

ANSWER: C

## QUESTION NO: 3

What grade of plywood is recommended for use with ICT systems?

- A. A/C
- B. A/D
- C. C/D
- D. B/C

ANSWER: A

## QUESTION NO: 4

Which of the following is a building-serving space that houses large pieces of common active equipment?

- A. TR
- B. ER
- C. TE
- D. Mechanical Room
- E. Battery room

**ANSWER: B**

## QUESTION NO: 5

Which of the following may provide a demarcation point between the service provider and the customer premises cabling?

- A. Telecommunications room
- B. Work area
- C. Telecommunications enclosure
- D. Entrance facility

**ANSWER: D**

## QUESTION NO: 6

Which of the following is a floor serving space that serves as a point of termination for horizontal and backbone cables?

- A. EF
- B. TR
- C. ER
- D. Work area

**ANSWER: B**

## QUESTION NO: 7

Which of the following is permissible if the available firestop assembly is NOT capable of properly restoring the necessary fire rating?

- A. Substitute products from another assembly
- B. Add more of the product to increase the rating
- C. Obtain written assistance from the manufacturer
- D. Move the installation to another location

**ANSWER: C**

## QUESTION NO: 8

Which phase of testing includes documenting the test results?

- A. Phase 1
- B. Phase 2
- C. Phase 3

**ANSWER: C**

## QUESTION NO: 9

Which of the Two organizations jointly oversee the worldwide standardization of telecommunications cabling?

- A. Alliance for Telecommunications Industry Solutions (ATIS) and Society for Cable Telecommunications Engineers (SCTE)
- B. National Electrical Contractors Association (NECA) and National Fire Protection Association (NFPA)
- C. Comite Europeen de Normalisation Electrotechnique (CENELEC) and Electronic Industries Association (EIA)
- D. International Organization for Standardization (ISO) and International Electrotechnical Commission (IEC)

**ANSWER: D**

## QUESTION NO: 10

Which of the refers to a rule or set of rules intended to endure safety during the installation and use of materials, components, fixtures, systems, premises and related subjects?

- A. Standard
- B. Directive
- C. Code
- D. Regulation

**ANSWER: C**