

DUMPSBOSS.

HCNA Data Center Facility

Huawei H12-411

Version Demo

Total Demo Questions: 10

Total Premium Questions: 184

Buy Premium PDF

<https://dumpsboss.co>

support@dumpsboss.co

support@dumpsboss.co
dumpsboss.co

QUESTION NO: 1

When mains input range of voltage: 150-260VAC, frequency: 45-60HZ, which of the following UPS working range can work in the main inverter state?

- A. Input range: 180 - 240V, 45 - 55HZ
- B. Input range: 160 - 280V, 45 - 65HZ
- C. Input range: 180 - 240V, 40 - 70HZ
- D. Input range: 110 - 280V, 40 - 70HZ

ANSWER: D

QUESTION NO: 2

The main features of MCB circuit breakers include shutoff protection and overload protection.

- A. True
- B. False

ANSWER: A

QUESTION NO: 3

For valve-regulated lead-acid batteries, what are the role of safety valve? (Multiple choice)

- A. Exhaust excess gas
- B. prevent air from entering
- C. Conductive
- D. Participate in chemical reactions

ANSWER: A B

QUESTION NO: 4

Which of the following function is supported by Huawei NetEco monitoring system? (Multiple choice)

- A. Configuration Management
- B. Alarm Management
- C. Access Management
- D. Battery monitoring

ANSWER: A B C D

QUESTION NO: 5

At present, batteries are installed in data centers mainly in rack-mounted and tank-mounted installations.

- A. TRUE
- B. FALSE

ANSWER: A

QUESTION NO: 6

According to different categories by electrolyte! the batteries can be divided into () and (). (Multiple Choice)

- A. lead acid batteries
- B. alkaline batteries
- C. lean liquid battery
- D. flooded battery

ANSWER: A B

QUESTION NO: 7

Which of the following options do not qualify as direct expansion air-cooled air conditioners?

- A. Simple structure, easy installation, low cost
- B. Refrigeration energy efficiency is relatively low
- C. Installation distance is unlimited
- D. can not be installed over long distances, or large loss of refrigeration

ANSWER: C

QUESTION NO: 8

Computer room air conditioning is suitable for () scenes. (Multiple choice)

- A. Modular data center
- B. Container Data Center
- C. Large and medium-sized data center
- D. Office

ANSWER: A B C

QUESTION NO: 9

() is used to ensure that the extinguishing agent is sprayed in a specific jet to promote the rapid vaporization of the extinguishing agent and to achieve the extinguishing concentration within the protected space.

- A. Nozzle
- B. Fire network
- C. Start the device
- D. extinguishing agent bottle group

ANSWER: A

QUESTION NO: 10

Which of the following belongs to the indirect-contact heat and humidity treatment equipment? (Multiple Choice)

- A. Cooling coil
- B. Coil air heater
- C. Electrode humidifier
- D. Evaporator

ANSWER: A B D